# **GYDAD** INTERNATIONAL



## **Description:**

The temperature probe TFP 100 was developed mainly for tank mounting. The PT 100 precision resistor in 4-conductor design can be connected directly to HYDAC temperature switches ETS 3800, ETS 380 and ETS 1700 using the connector supplied.

The standardised electrical connection also means that other evaluation or control systems (e.g. PLC) can easily be connected.

For adaptation to different applications and fluids, a nickel-plated brass mounting sleeve which is pressure resistant up to 10 bar is also available as an accessory.

## **Special features:**

- Measurement circuit configured as four-conductor circuit
- Simple to install
- For universal application

## **Pin connections:**



| Pin |          |          |
|-----|----------|----------|
| 1   | + Supply | + Supply |
| 2   | + Signal | + Signal |
| 3   | - Signal | - Signal |
| 4   | - Supply | - Supply |

## **Temperature Probe** TFP 100

## **Technical specifications:**

| Temperature probe TFP 100   |  |  |  |
|---|--|--|--|
| Temperature range   | -40 +125 °C (-40 +257 °F)                                |  |  |
| Electrical connection   | Male Binder series 714 M18, 4 pole<br>Male M12x1, 4 pole |  |  |
| Parts in contact with fluid   | Brass  |  |  |
| <b>( (</b> mark   | EN 61000-6-1 / 2 / 3 / 4                                 |  |  |
| Supply voltage  | 9 35 V DC  |  |  |
| Protective sleeve for tank-mounting the TFP 100 (Accessory, not supplied as standard) |  |  |  |
| Pressure resistance   | 10 bar   |  |  |
| Parts in contact with fluid   | CuZn39Pb3 (brass), nickel-plated                         |  |  |

## Model code:



#### Separate temperature probe

#### Electrical connection

- 4 = 4 pole Binder series 714 M18, male (connector supplied)
- 6 = 4 pole M12x1, male (connector not supplied)

#### Modification number \_

000 = Standard

#### **Dimensions:**









Ø8.0,1

### Note:

The information in this brochure relates to the operating conditions and applications described.

For applications and operating conditions not described, please contact the relevant technical department.

Subject to technical modifications.

## HYDAC ELECTRONIC GMBH

Hauptstraße 27, D-66128 Saarbrücken Tel. +49 (0)6897 509-01 Fax +49 (0)6897 509-1726 E-Mail: electronic@hydac.com Internet: www.hydac.com

(HYDAC) 1